


- NOTES**
1. Verifying Dimensions.
The contractor shall verify dimensions against such other drawings or site conditions as pertain to this part of the work.
 2. Existing Services.
Any information concerning the location of existing services indicated on this drawing is intended for general guidance only. It shall be the responsibility of the contractor to determine and verify the exact horizontal and vertical alignment of all cables, pipes, etc. (both underground and overhead) before work commences.
 3. Issue of Drawings.
Hard copies, dwf and pdf will form a controlled issue of the drawing. All other formats (dwg, dxf etc.) are deemed to be uncontrolled issues and any work carried out based on these files is at the recipient's own risk. RPS will not accept any responsibility for any errors arising from the use of these files, either by human error by the recipient, listing of un-dimensioned measurements, compatibility issues with the recipient's software, and any errors arising when these files are used to aid the recipient's drawing production, or setting out on site.
 4. Datum: ITM



Luminaire A Data:
 Supplier: Philips
 Type: BGP704 DW10
 Lamp(s): LED-HB 5.2S 740
 Lamp lumens: 23000
 Light Loss Factor: 0.84
 Height: 12.0m

Luminaire F Data:
 Supplier: HESS
 Type: RENO ELEMENTS TOP
 LIGHT LR LEVO3L
 Lamp(s): 2X16LED 27W 245mA
 Lamp lumens: 2972 2700/80
 Light Loss Factor: 0.84
 Height: 4.50m

Luminaire J Data:
 Supplier: LUCELIGHT
 Type: STRA 2.0
 Lamp(s): High Intensity LEDs
 Lamp lumens: 1248
 Light Loss Factor: 0.84
 Height: 1.0m

Luminaire L Data:
 Supplier: SCULPLINE
 Type: SCULPLINE R50 6291 Diffuser P25
 Lamp(s): 5 OSLOM SSL 150@350mA NW 840
 Lamp lumens: 526 nw 40000K/80
 Light Loss Factor: 0.84
 Height: 0.35m

Luminaire M Data:
 Supplier: SCHREDER
 Type: ALINEA 5121-3 LED 350mA WW Profiled
 poly Clear, Smooth WO-7
 Lamp(s): 3 LED'S
 Lamp lumens: 367
 Light Loss Factor: 0.84
 Height: 1.03m

Rev	Date	Dim	Chk	Amendment / Issue	App
P01	27/06/24	ME	DK	Issue for Planning	DK
C01	18/10/23	ME	DK	Issue for Planning	DK

Client
COMHLAUGHT CHALAFORT
ATHA CLIAITH
DUBLIN PORT COMPANY

ENGINEERING
 M&S Building
 Bond Road Extension
 Dublin 3

Tel. 00 353 1 8555771
 Fax. 00 353 1 8550487

rps MAKING COMPLEX EASY
 Innishmore, Ballincollig,
 Co Cork, Ireland.
 T +353 21 4665900
 W www.rpsgroup.com/ireland
 E ireland@rpsgroup.com

Project
3FMProject Bringing Dublin Port To 2040

Title
 Roads & Footways (Southern & SPAR) -
 Proposed Lighting
 Sheet 3

Model File Identifier

File Identifier
 CP1901_3FM-RPS_S26-HLG-XX-DR-LE-1300-0003

Created on	18/10/2023	Sheets	1
Scale	1:500 @ A1 1:1000 @ A3	Status	S4
		Rev	P01